ASTRA DOOR CONTROLS AST4002 DECLARATION OF PERFORMANCE

Number:

AST8006

Unique identification code of the product type:

AST4002 (BFS, CFS, SFS, DBS, ABS, BZS, CPS, BFR, CFR, SFR, DBR, ABR, BZR, CPR) concealed door control.

Type, batch or serial number or any other element allowing identification of the product:

AST4002 series concealed door control.

Intended use or uses of the product, in accordance with the applicable specification, as foreseen by the manufacturer:

For use on fire and smoke compartmentation doors, when fitted in accordance with the manufacturers fitting instructions.

Name, registered trade name or registered trade mark and contact address of the manufacturer:

Astra Door Controls, Astra Business Centre, Roman Way, Preston PR2 5AP, United Kingdom.

General	AST4002 Concealed Door Control	
Application	Concealed in the door blade.	
Durability	500,000 test cycles.	
Closing moment	Power size 2.	
Opening moment	Power size 2.	
Efficiency	more than 70%.	
Closing time: was capable of adjustment to	After 5,000 and 500,000 test cycles, the closing time from an open angle of 90° o 3 seconds or less, and 20 seconds or more. After 500,000 test cycles, the closing	
time set at 5,000 test cycles did not increase by more than 100% or decrease by more than 30%.		
Angles of operation	Up to 105°.	
Temperature dependence	-15°C to +40°C.	
Latch control	Effective over maximum range of 15° from closed position.	

Declared Performance:

Performance Criteria	
Durability	Pass – 500,000 test cycles.
Corrosion	Grade 3.
CorrosionPass – after the salt spray test, the closing moment of the door closer was notless than 80% of that measured prior to the test.	
Dangerous substances substances in excess of the regulations.	The materials in the product(s) do not contain or release any dangerous maximum levels specified in existing European material standards or any national

Signed for and behalf of the manufacturer by:

Date of issue 2nd April 2018

Astra Door Controls Limited

Astra Business Centre, Roman Way, Preston PR2 5AP, United Kingdom